SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

CementPro

3929 E Guasti Rd. Unit C, Ontario, CA, United States

For the following product(s):

Sealants:

Elastic Pro, Grout Sealer, Poly-Pro Non Sanded Grout, Poly-Pro Sanded Grout

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

Indoor Advantage™ Gold

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method (CA 01350) v1.2-2017 for the school classroom, private office, and single-family residence parameters when modeled as Flooring. Also, conforms to the SCAQMD Rule 1168 - Adhesive and Sealants (January 2005). Standard Product Application Amount: 171 g/m2

Measured Concentration of Total Volatile Organic Compounds (TVOC): 0.5 mg/m3 or less (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Methylene Chloride and Perchloroethylene are not intentionally added to certified products

Registration # SCS-IAQ-09457

Valid from: October 10, 2023 to October 9, 2024







Tranky Mather Kam

Stanley Mathuram, PE, Executive Vice President SCS Global Services 2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA